

Addendum No. 1 Receipt Certification

Project	Pump Station Upgrade Program Walden Woods, Jefferson Valley and Jefferson Park	Project No.	8618742
Owner	Town of Yorktown, New York	Date	December 18, 2018

Addendum No. 1 - Receipt Certification

Each Addendum Receipt Certification is to be submitted with the bid. Failure to submit the Addendum Receipt Certification may result in rejection of the bid.

certify that on the have received Addendum No. 1 consisting of 3 pages. Pump Station Upgrade Program, Walden Woods, Jefferson Valley and Jefferson Park, Bid #16-5 Rd acknowledge all terms, conditions and modifications to the bid documents.		
	Bidder (Company)	
	Authorized Signer (Print)	
•	Signature	



Addendum No. 1 to Contract Documents

Project	Pump Station Upgrade Program Walden Woods, Jefferson Valley and Jefferson Park	Project No.	8618742
Owner	Town of Yorktown, New York		
Contract No.	1 – General 2 – Electrical	Date	December 18, 2018
Addendu	m No. 1 - Modifications to Contract Documents		•

To All Contractors:

Contractors submitting proposals for the above-named project shall take note of the following changes, additions, deletions, clarifications, etc., in the Contract Documents, which shall become a part of and have precedence over anything contrarily shown or described in the Contract Documents, and all such shall be taken into consideration and be included in the Contractor's bid proposal.

Item No. 1

Invitation to Bid. Replace the last sentence with the following:

"Bidders shall review and acknowledge all Addenda on the Bid Form and submit the addendum receipt certification with their bid"

item No. 2

invitation to Bid. Insert the following after the last sentence:

"Prospective bidders may request the pre-bid inspection attendance sheets by submitting a Freedom of Information Law request to the Town Clerk via email (dQuast@yorktownny.org)"

Item No. 3

Instructions to Bidders, Article 8.01. Replace Article 8.01 with the following:

"8.01 A Bid must be accompanied by Bid security made payable to Owner in an amount of 10 percent of Bidder's maximum Bid price and in the form of a certified check, bank money order, or a Bid Bond (on the form attached) issued by a surety meeting the requirements of paragraphs 5.01 and 5.02 of the General Conditions."

item No. 4

Instructions to Bidders, Article 15.01. Insert Article 15.01 with the following:

"J. Addendum Receipt Certifications (each addendum)"



item No. 5

Bid Form. Article 5,02. Delete Article 7.02.B.2.c

Item No. 6

Bid Form. Article 5.02. Replace Article 5.02.B.2.b with the following:

"b. Construction of the Jefferson Park pump station."

Item No. 7

Bid Form, Article 8.01. Insert the following:

"J. Addendum Receipt Certifications (each addendum)"

Item No. 8

Contract Drawing A001, Insert the following text beneath the Plaque Detail:

"PLAQUE REQUIREMENTS:

- CAST BRONZE.
- SATIN FINISH FOR RAISED BORDERS, GRAPHICS AND FACES OF RAISED LETTERS.
- 3. LEATHERETTE BACKGROUND TEXTURE WITH DARK OXIDE STAIN.
- 4. FACTORY-APPLIED PROTECTIVE COATING.
- 5. FLAT RELIEF TOWN OF YORKTOWN SEAL.
- 6. CONCEALED STUD MOUNT.
- SUBMIT DESIGN DRAWING UNDER SECTION 10441 FOR APPROVAL PRIOR TO FABRICATION.
- 8. AS MANUFACTURED BY MATTHEWS INTERNATIONAL, THE SOUTHWELL COMPANY, OR EQUAL."

item No. 9

Technical Specifications. Section 11310. Replace Article 2.01, first paragraph with the following:

"Furnish and install one prefabricated, above-grade, wet well-mounted pump station at the Walden Woods Pump Station. The complete unit shall be designed, fabricated, assembled and tested prior to shipment to the site.

Prefabricated pump station shall be by USEMCO, or equal."

Item No. 10

Technical Specifications. Section 11320. Replace the first paragraph of Article 2.01.A with the following:

"A. Pumps - The pumps provided under this section shall be Model XFP 1505J-CB2 by ABS, or equal."



Item No. 11

Technical Specifications. Section 16480, Article 2.01.A. <u>Delete</u> "Allen Bradley – 1336 (Plus) series" and <u>Replace</u> with "Allen Bradley – PowerFlex 750 Series"



Robert Butterworth, P.E.