

TOWN OF YORKTOWN
WESTCHESTER COUNTY, NEW YORK
DISINFECTION SYSTEM
ULTRAVIOLET LAMP REPLACEMENT

Capital Improvement Project #22-e3

ADDENDUM NO. 1

TO ALL BIDDERS:

This addendum is issued this day in conformance with Part Two, Section 3.4 of the Instruction for Bidders in the Contract Documents. The information contained in this Addendum supersedes, replaces, or supplements the Contract Documents and is made an integral part of the Contract. This Addendum must be attached to each bidder's contract and submitted along with his bid.

Now, herewith, all bidders shall take the following items into account when preparing their bid:

PART THREE

Qualification Requirements

Any bidder that proposes an "Or Equal" ultraviolet light system must provide with its bid package:

- a. Third-party validation of end of lamp life is deleted from the requirements.
- b. Provide a list of operational reference sites, indicating lamp type, make and model to demonstrate reliable performance
- c. Evidence that every technical specification item listed herein will be met.