

REQUEST FOR INFORMATION:

Yorktown Re-Bid for Air Conditioning at the Albert A Capellini Community and Cultural Center

RFI#1

Joe Lombardo Plumbing & heating of Rockland Inc. is requesting a Walk through for the bid @ Albert A. Capellini Community Center

Answer: For a walkthrough please contact Phil Marino, General Foreman (914) 962-5758

RFI#2

Is Carrier Enterprise equipment an equal to Johnson Controls Air Cooled Units & Air Handling Units?

Answer: Carrier can be a substitution for JCI as long as the performance specifications are met. This selection by the contractor should be reviewed with Yorktown Facilities.

RFI#3

Please provide the milestone for the project

Answer: The Contractor is asking for a milestone schedule. I would like them to start as soon as possible.