



DAVID A. TETRO • ARCHITECT, P.C.

302 LEWIS AVENUE • YORKTOWN HEIGHTS • NY • 10598

T 1.914.962.3113 E dtetarchitect@gmail.com www.davidtetroarchitect.com



ADDENDUM #1

- FOR -

TOWN OF YORKTOWN HIGHWAY GARAGE
281 UNDERHILL AVENUE
YORKTOWN HEIGHTS, NY

JUNE 5, 2024

RE: DUPLEX OUTLETS WITHIN TOILET ROOMS

THE FOLLOWING ITEMS ARE TO BE INCLUDED IN THE CONTRACT SCOPE OF WORK AND SHALL BE PROVIDED BY THE GENERAL CONTRACTOR AND THEIR SUB-CONTRACTORS AS REQUIRED. CONTRACTOR SHALL REFERENCE THE BASE CONTRACT DOCUMENTS INDICATED ABOVE. UNDER NO CIRCUMSTANCES SHALL THIS DOCUMENT BE CONSTRUED AS A STAND ALONE ITEM. THE ITEMS WITHIN THIS ADDENDUM SHALL SUPERSEDE THOSE ITEMS ON THE BASE CONTRACT DOCUMENTS UNLESS SPECIFICALLY INDICATED HEREON.

Reference: Duplex GFCI

- A duplex GFCI outlet, per code, is to be provided at each lavatory.

END OF ADDENDUM #1