

**From:** [Diana Quast](#)  
**To:** [Anthony Rosati](#)  
**Cc:** [Maura Weissleder](#)  
**Subject:** RE: RFI - Fencing at Pickleball Courts at Tom Diana Park - Yorktown  
**Date:** Thursday, September 12, 2024 1:19:17 PM

---

Goo0d morning Diana.

I am reviewing the bid in connection with the above referenced project. Just had a couple of quick questions:

1.) Is a bid bond/payment & performance bond required? The documents state that the information would be in the Instructions to Bidders". There is no information. Are we to assume that it is waived?

**No bonds required**

2.) Are permits required from the town? **Yes, but fee waived for town project**

3.) Regarding the removal and disposal of existing 4ft high and 6ft high fences, is it acceptable to remove footings to a depth of approximately 6" below grade? Or are footings to be removed in their entirety? **In there entirety**

4.) All posts for new 8ft high fencing (line posts, and end posts) shall be 3" in diameter, correct?

**Correct**

5.) Posts for new 4ft high fencing shall consist of 3" diameter end posts, and 2-1/2" diameter line posts, correct? **Correct**

6.) What size posts are required for the gate posts? Is 3" in diameter acceptable? **Yes**

7.) What size pipe is required to be used for the gate frames? 1-5/8" in diameter? 2" in diameter?

**2"**

8.) What type of pipe shall be used? SS20? SS40? **SS40**

9.) Is there a drawing available depicting the layout? **Current Fence on location, bidder welcome to site visit.**

10.) Is there a detail available depicting the fence? **No**

---

**From:** Anthony Rosati <anthony@scrinc.co>  
**Sent:** Thursday, September 12, 2024 9:21 AM  
**To:** Diana Quast <dquast@yorktownny.org>  
**Cc:** Eric Spitale <eric@scrinc.co>  
**Subject:** RFI - Fencing at Pickleball Courts at Tom Diana Park - Yorktown

**CAUTION:** This email originated from outside of the organization. Do not click links or open attachments unless you

recognize the sender and know the content is safe.

Good morning Diana.

I am reviewing the bid in connection with the above referenced project. Just had a couple of quick questions:

- 1.) Is a bid bond/payment & performance bond required? The documents state that the information would be in the Instructions to Bidders". There is no information. Are we to assume that it is waived?
- 2.) Are permits required from the town?
- 3.) Regarding the removal and disposal of existing 4ft high and 6ft high fences, is it acceptable to remove footings to a depth of approximately 6" below grade? Or are footings to be removed in their entirety?
- 4.) All posts for new 8ft high fencing (line posts, and end posts) shall be 3" in diameter, correct?
- 5.) Posts for new 4ft high fencing shall consist of 3" diameter end posts, and 2-1/2" diameter line posts, correct?
- 6.) What size posts are required for the gate posts? Is 3" in diameter acceptable?
- 7.) What size pipe is required to be used for the gate frames? 1-5/8" in diameter? 2" in diameter?
- 8.) What type of pipe shall be used? SS20? SS40?
- 9.) Is there a drawing available depicting the layout?
- 10.) Is there a detail available depicting the fence?

Thanks,

Anthony Rosati  
General Manager  
SCR Fence  
Spitale Construction Resources Inc  
2013 Crompond Rd Ste 3  
Yorktown Heights, NY 10598  
Office: (914) 352-6366  
Mobil: (646)208-8392