

ADDENDUM NO. 3

FRENCH HILL WATER TANK REHAB BID TOWN OF YORKTOWN WATER DEPARTMENT

To All Bidders:

The information contained in this Addendum supersedes, replaces, or supplements the Contract Documents and is made an integral part of the Contract. *This Addendum must be attached to each bidder's contract and submitted along with the bid.*

Please be advised of the following additions/changes to the above-referenced bid document.

1) Section 09 97 13, Subpart 2.02, replace the following:

2.02.C(2).b(1), replace "Sherwin Williams "Macropoxy 646 Fast Cure Epoxy" 5-7 mils" with "Sherwin Williams Hi-Solids Polyurethane 250 Semi-Gloss 3-5 mils DFT"

2.02.C(2).c(1), replace "Sherwin Williams "Sher-Loxane 800" DFT 4-6 mils" with "Sherwin Williams Fluorokem® HS 100 SemiGloss 2-3 mils DFT"

2) Drawing C-100

Scope of Work Section, replace Exterior Coating System with:

EXTERIOR (COATING SYSTEM NUMBER: AWWA D102 OCS#4)

1. BLAST EXISTING COATING SYSTEM TO ACHIEVE THE EQUIVALENT OF SSPC-SP6 SURFACE PREPARATION
2. PRIMER: SHERWIN-WILLIAMS B65G00011 – COROTHANE 1 GALVAPAC 1K ZINC PRIMER, 3-4MILS DFT
3. INTERMEDIATE: SHERWIN-WILLIAMS B65WJ0351 – HI-SOLIDS POLYURETHANE 250 SEMI-GLOSS 3-5MILS DFT
4. TOPCOAT: SHERWIN-WILLIAMS B65W01570 – FLUOROKEM® HS 100 SEMI-GLOSS 2-3MILS DFT

DIANA L. QUAST, TOWN CLERK
MASTER MUNICIPAL CLERK

Dated: October 3, 2024