

FRENCH HILL TANK REHAB BID
Q&A No. 1

In the summary of work, section 01 11 00, 1.02 Project Description, it states just a rehabilitation to the exterior of the tank. On the drawings, page C-100 for the scope of work it states Exterior and Interior coatings work. **The interior is a bid alternate but mixers are part of the exterior pricing**

Is this job a full removal/sandblast of both the interior and exterior coatings and applying new coatings to both the exterior and interior? **Yes full removal/sandblast of exterior and interior . Interior is going to be a bid alternate**

Is this bid now open to the public or to the contractors that went to the original mandatory pre-bid meeting on the previous bid on 9/5/24 at 10am? **The bid is open to the public**

Is Woodard & Curran the engineers on this project? **YES**

Do we direct questions to you, or them or to whom? **YOU CAN DIRECT QUESTIONS TO ME (Paul Vasillo, (914)245-6111)**

There are no dates in the package for when this work can start? When can the work start? **ONCE BID IS AWARDED WE WOULD LIKE TO START ASAP**

How many days do we have to complete the project? **YEARS END**

Tank will be drained for this project correct? **YES**

Will water be on site and available during our work while the tank is emptied? **YES**

Since the original bid was part of other tanks in the system, does the draining of this tank have to be coordinated with the other tanks still? **I WILL COORDINATE WITH NWJWW**