

FRENCH HILL TANK REHAB BID
Q&A No. 4

Is Robotic blasting acceptable for the tank exterior? **Robotic sandblasting is acceptable, supplemented by non-robotic means where necessary due to tank geometry or appurtenances.**

What method was used for the lead testing? Was a TCLP test utilized or was a totals analysis run? **Lead was analyzed by EPA 6010, prepared by method EPA 3050B.**