

TOWN OF YORKTOWN
WESTCHESTER COUNTY, NEW YORK

CCTV WORK

Capital Improvement Project #24-9

ADDENDUM NO. 1

TO ALL BIDDERS:

This addendum is issued this day in conformance with Part Two, Section 3.4 of the Instruction for Bidders, in the Contract Documents. The information contained in this Addendum supersedes, replaces, or supplements the Contract Documents and is made an integral part of the Contract. This Addendum must be attached to each bidder's contract and submitted along with his bid.

Now, herewith, all bidders shall take the following items into account when preparing their bid:

1. Most of the sewer lines in the project area are in ROWs. An interactive map of the Town's sanitary sewer system can be found at the following link:

<https://yorktown.maps.arcgis.com/apps/mapviewer/index.html?webmap=5d72917026af491e9c6b26141623d6f6>

2. The sewer lines in the project area are predominately 8-inches in diameter. It is estimated that approximately 15% of the lines are 12-inches. There are no lines larger than 12-inches.
3. The bid assumes the amount of pipe cleaning for proper inspection of the lines. The actual amount of cleaning will be determined during the inspection process.
4. The contractor will supply NASSCO compliant files that can be loaded into ArcGIS.